



## Water Hardness per System (October 2022)

Water System Number	Water System Name	General Area	Parts per Million (PPM)		Grains per Gallon (GPG)		Iron (PPM)
			Range	Average	Range	Average	Average
10-010	Tangerine Business Park	Tangerine Road/Breakers Road	110 (1 Well)	110	6	6	<0.050
10-092	Picture Rocks	Continental Reserve/Picture Rocks/Cortaro & Silverbell	210 to 210 (2 Wells)	210	12	12	<0.050
10-136	Palo Verde	Twin Peaks & Clayton	200 (1 Well)	200	12	12	<0.050
10-138	Airline/Lambert	Avra Valley Rd/ Airline Rd/Lambert Ln/Saguaro Bloom/Silverbell Rd & Linda Vista	180 (1 Well)	180	11	11	<0.050
10-150	Marana Municipal	Gladden Farms/Rancho Marana/Honea Heights/Yoem Pueblo/Marana Main Street	130 to 230 (2 Wells)	180	8 to 13	11	<0.050
10-150	Marana Municipal	San Lucas/Warfield Circle/Amole Circle	95 (1 Well)	95	6	6	<0.050
10-329	Hartman Vistas	Hartman Vistas/Hartman 10/Oasis Hills/Oshrin Park/Cortaro Crossings/Shady Grove/Red Rock Village/Willow Ridge/Twin Peaks & I-10	53 to 120 (3 wells)	80	3 to 7	5	<0.050
10-406	Airport	Marana Regional Airport	210 (1 wells)	210	12	12	0.056