

EXHIBIT E TO MARANA RESOLUTION No. 2019-032

**Town of Marana Amendments to the 2018 International Mechanical Code**

**Section 101.1 Title.** REVISE section by inserting Town of Marana

**Section 103.4 Liability.** REVISE section by **DELETING** board of appeals and **REPLACING** it with Board of Adjustment

**Section 106.2 Permits not required.** REVISE section as follows with **DELETIONS** shown with ~~strikeouts~~ and **ADDITIONS** shown with double underlining:

6. Replacement of Portable evaporative coolers with like coolers.

**Section 106.5.2 Fee schedule.** **DELETE** section in its entirety and **REPLACE** with “The fees for mechanical work shall be in accordance with the Town of Marana Fee Schedule.”

**106.5.3 Fee refunds.** REVISE by **INSERTING** 80% in both blanks that state “SPECIFY PERCENTAGE”.

**Section 108.4 Violation penalties.** REVISE section as follows with **DELETIONS** shown with ~~strikeouts~~ and **ADDITIONS** shown with double underlining:

Persons who shall violate a provision of this code or shall fail to comply with any of the requirements thereof or who shall erect, install, alter or repair mechanical work in violation of the *approved construction documents* or directive of the code official, or of a permit or certificate issued under the provisions of this code, shall be ~~in violation guilty of a [SPECIFY OFFENSE], punishable by a fine of not more than [AMOUNT] dollars or by imprisonment not exceeding [NUMBER OF DAYS], or both such fine and imprisonment. Each day that a violation continues after due notice has been served shall be deemed a separate offense.~~ Violation penalties are set forth in Marana Town Code Title 7, section 7-1-5.

**Section 108.5 Stop work orders.** REVISE section as follows with **DELETIONS** shown with ~~strikeouts~~ and **ADDITIONS** shown with double underlining:

Upon notice from the code official that mechanical work is being performed contrary to the provisions of this code or in a dangerous or unsafe manner, such work shall immediately cease. Such notice shall be in writing and shall be given to the owner of the property, or to the owner’s authorized agent, or to the person doing the work. The notice shall state the conditions under which work is authorized to resume. Where an emergency exists, the code official shall not be required to give a written notice prior to stopping the work. Any person who shall continue any work on the system after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be in violation. ~~liable for a fine of not less than [AMOUNT] dollars or more than [AMOUNT] dollars.~~ Violation penalties are set forth in Marana Town Code Title 7, section 7-1-5.

**Section 109 MEANS OF APPEAL.** **DELETE** subsections 109.1 through 109.7 and **REPLACE** with “The means of appeal are set forth in Marana Town Code Title 7, section 7-1-6.”

**Section 307.2.1 Condensate disposal.** REVISE section by **ADDING** the following at the end of the paragraph:

Condensate disposal shall be allowed to terminate as follows:

1. Into an approved fixture tailpiece, funnel drain, waste air gap fitting, floor sink, slop sink, and laundry tray.
2. At or below grade outside the building in an area capable of absorbing the condensate flow without surface drainage.
3. Over roof drains or gutters or downspouts that connect to drainage pipes, provided they terminate at or above grade in an area capable of absorbing the condensate flow without surface drainage.

**Section 1004.1 Standards,** REVISE section as follows with **ADDITIONS** shown with double underlining:

**1004.1 Standards.** Boilers shall be designed, constructed and certified in accordance with the ASME *Boiler and Pressure Vessel Code*, Section I or IV and Arizona Boiler Rules, Title 20, Chapter 5. Controls and safety devices for boilers with fuel input ratings of 12,500,000 Btu/hr (3,662,500 W) or less shall meet the requirements of ASME CSD-1. Controls and safety devices for boilers with inputs greater than 12,500,000 Btu/hr (3,662,500 W) shall meet the requirements of NFPA 85. Packaged oil-fired boilers shall be listed and labeled in accordance with UL 726. Packaged electric boilers shall be listed and labeled in accordance with UL 834. Solid-fuel-fired boilers shall be listed and labeled in accordance with UL 2523.